



NOTE:

1. BACKFLOW PREVENTER INSTALLATION MAXIMUM OF 10' DOWNSTREAM OF METER.
2. BACKFLOW PREVENTER INSTALLED, OWNED & MAINTAINED BY CUSTOMER.
3. O.U.C. CROSS-CONNECTION CONTROL DEPARTMENT 407-649-4436.



ORLANDO UTILITIES COMMISSION
 WATER BUSINESS UNIT
 3800 Gardenia Orlando, FL 32839

ENG.: W.E.	DATE: 03-30-09
DRAWN: WETS	MAP SEC. N/A
W.R. No. N/A	SCALE: N.T.S.
ACAD No.: N/A	FILE: RPZ-SMALL.DWG

REDUCED PRESSURE ZONE